

SEALANT COMPATIBILITY CHART

With DriStud Cool Window Flashing Tape

PROCEDURE

Submitted samples were tested according to AAMA 713-08 “Voluntary Test Method to Determine Chemical Compatibility of Sealants and Self-Adhered Flexible Flashings”, using test temperatures of 5°C, 30°C, 60°C, and 80°C.

Sealant samples tested with DriStud Cool Window Flashing Tape

1. Dowsil 758
2. Dowsil 790
3. Dowsil 795
4. Gorilla Firestop MS
5. Fix HG MS
6. Fixall 220 MS
7. MasterSeal NP 150
8. Sika AT
9. SikaMS

REQUIREMENTS

- No Slump exceeding 9.5mm
- No Observed liquification
- No extreme discolouration
- No visible degradation of self-adhered flashing adhesive or sealant

RESULTS

Manufacturer / Product	Compatibility	
Dow		
Dowsil 758	Yes	
Dowsil 790	Yes	
Dowsil 795	Yes	
Holdfast		
Gorilla Firestop MS	Yes	
Fixall HG MS	Yes	
Fixall 220 MS	No	<i>Complies at 5°C, 30°C, 60°C but not 80°C.</i>
BASF		
MasterSeal NP 150	No	
SIKA		
Sika AT	No	
Sika MS	No	

Date testing completed: 24/04/2019



Distributed by TCL Hunt
7 Fisher Crescent, Mt. Wellington
Auckland, New Zealand

For further information please visit www.dristud.co.nz or call 0800 DRISTUD (374 7883).